

Government of Bihar
Public Health Engineering Department
Water Quality Report
Division Name: Public Health Engineering Division, Bihar Sharif & Hilsa

District Name: Nalanda

District Name: Nalanda							Date of Sampling :- 03/08/2026															Source of Water
Sample Collected by :- Vijay Kumar							Test result															
Sl. No.	Block	Panchayat	Village	Habitation	Wd no	Location of Source	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F			
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21		
1	Noorsarai	Nari	Nari More	Nari Main Road	2	LOYOLA CONVENT SCHOOL, Biharsharif (Nalanda)	7.53	0.45	340	230	120	32	9.6	20	110	0.1	<1.0	10.5	0.654	Tap Water		
Desirable Limit							6.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1	-		
Permissible Limit* in absence of alternate source							NR	5	-	2000	600	200	100	1000	600	NR	NR	400	1.5	-		

Sweta
MANAGER
LOYOLA CONVENT SCHOOL

Principal
LOYOLA CONVENT SCHOOL
Nari More Bihar Sharif-803101

Chemist
05/08/2026
Public Health Division, Bihar Sharif
(Nalanda)
Chemist
Public Health Division
Bihar Sharif (Nalanda)